QANAT قناة

Product specification

LPG

Property	Test method	Unit	Propane	Butane
Vapour pressure at 37.8 °C (gauge)	ASTM D1267	kPa	≤ 1434	≤ 485
95% evaporated temperature	ASTM D1837	°C	≤ −38.3	≤ 2.2
Butane and heavier	ASTM D2163	% vol	≤ 2.5	—
Pentane and heavier	ASTM D2163	% vol	—	≤ 2.0
Residue on evaporation of 100 mL	ASTM D2158	mL	≤ 0.05	≤ 0.05
Total sulphur	ASTM D6667	mg/kg	≤ 185	≤ 140
Copper strip corrosion	ASTM D1838		No. 1	No. 1
Free water	—		None	None

Typical values for reference. The specification in the contract and the supplier's certificate of analysis are binding.

qanatenergy.com · desk@qanatenergy.com · +964 771 771 9191